



30th June 2026

REFERENCE NUMBER: SPD3/2026/038

SPD3/2025/038 – TENDER FOR THE GOZO REGIONAL COUNCIL'S ADMINISTRATIVE BUILDING REHABILITATION, INCLUDING, CONSTRUCTION, ALTERATIONS, RESTORATION AND FINISHING WORKS, USING ENVIRONMENTALLY FRIENDLY MATERIALS

Reference is made to the above-captioned tender for which the deadline for submission of offers is 14/07/2026 at 09:30am.

Clarification Note 2

CLARIFICATION REQUESTS

Question 1 Sheet 12) ELVs - Item 12.27: Would a purple UTP Cat6 cable be considered acceptable? provided that it fully complies with all the specified technical requirements and standards.

Answer 1 Tenderers are to comply with the technical specifications outlined in Section 3 – Specifications/Terms of Reference of the tender document.

Question 2 With regards to the tender specifications, clause 22.4, kindly specify where push bars are required.

Answer 2 As per the tender drawings, the fire doors do not open in the direction of travel; therefore, push bars are not required. Tenderers are to refer to Section 3 – Specifications/Terms of Reference, Clause 22.4, together with the applicable drawings.

Question 3 With regards to the tender specifications, clause 22.10, kindly specify where push plates or kick plates are required.

Answer 3 Kick plates shall be installed on all fire doors on the external side (i.e. in the direction of door opening), in accordance with Section 3 – Specifications/Terms of Reference, Clause 22.10 of the tender document.

Question 4 With regards to the tender BOQ 18) Fire doors points 18.01 and 18.02, kindly specify what style is required and provide any drawings of the doors.



Answer 4 Tenderers are to comply with the technical specifications set out in Section 3 – Specifications/Terms of Reference, Clause 22.5 of the tender document, which govern the requirements related to fire door design, configuration, and any associated drawings.

Question 5 Kindly confirm that hinges for fire rated doors, as per manufacturers test certificate are acceptable.

Answer 5 Tenderers are to comply with the technical specifications outlined in Section 3 – Specifications/Terms of Reference, Clauses 22.12 and 22.13, which specify the requirements for hinges and the submission of the manufacturer’s test certification.

Question 6 Kindly confirm that brushed steel or chrome plated hinges are acceptable.

Answer 6 Tenderers are required to comply with Section 3 – Specifications/Terms of Reference, Clause 22.12, which stipulates that hinges shall be of stainless steel type.

All other tender documents, conditions and requirements, which are not superseded by this clarification remain in place.
